

Certificado de Calibración para la evaluación IEC 61000-4-30 Clase A

Analizador de Red Portátil MYeBOX 150 & 1500

IEC 61000-4-30
230V~, 50/60Hz, L-N

Sección 61000-4-30	Parámetro Calidad de Red	Conforme Clase A	Conforme Clase S
5.1	Frecuencia Industrial	PASA	PASA
5.2	Amplitud de la tensión de suministro	PASA	PASA
5.3	Flicker	PASA	PASA
5.4	Huecos de tensión y sobretensión	PASA	PASA
5.5	Interrupciones de la tensión de suministro	PASA	PASA
5.7	Desequilibrio de la tensión de suministro	PASA	PASA
5.8	Armónicos de tensión	PASA	PASA
4.6	Incertidumbre del reloj de tiempo	PASA	PASA

Viladecavalls, 23 de Mayo 2018

Pedro Barcelona Ureña

Responsable de Laboratorio




Carlos Córcoles Brualla

Responsable de producto



Certificate of Calibration for IEC 61000-4-30

Class A assessment

MYeBOX 150 & 1500 Portable Power Analyzer

IEC 61000-4-30

230V~, 50/60Hz, Ph-N

61000-4-30 Section	Power Quality Parameter	Class A Compliance	Class S Compliance
5.1	Power frequency	PASS	PASS
5.2	Magnitude of the supply voltage	PASS	PASS
5.3	Flicker	PASS	PASS
5.4	Supply voltage dips and swells	PASS	PASS
5.5	Voltage interruptions	PASS	PASS
5.7	Supply voltage unbalance	PASS	PASS
5.8	Voltage harmonics	PASS	PASS
4.6	Time-clock uncertainty	PASS	PASS

Viladecavalls, May 23th 2018

Pedro Barcelona Ureña

Laboratory Manager




Carlos Córcoles Brualla

Product Manager

