

## Kit EFM-CDP

8-S  
8-S-PRO  
10-S  
10-S-PRO



	<b>¡IMPORTANTE!</b>
	Antes de efectuar cualquier operación de instalación, reparación o manipulación de cualquiera de las conexiones del kit debe desconectar los aparatos de toda fuente de alimentación, tanto alimentación como de medida. Cuando sospeche un mal funcionamiento de alguno de los equipos del kit, póngase en contacto con el servicio posventa.
	El fabricante del kit no se hace responsable de daños cualesquiera que sean en caso de que el usuario o instalador no haga caso de las advertencias y/o recomendaciones indicadas en esta guía ni por los daños derivados de la utilización de productos o accesorios no originales o de otras marcas.
	<b>¡IMPORTANTE!</b>
	Se recomienda consultar los manuales específicos de los equipos que forman el kit, antes de realizar la instalación.
	<b>¡IMPORTANTE!</b>
	Tener en cuenta que con los equipos conectados, los bornes pueden ser peligrosos al tacto, y la apertura de cubiertas ó eliminación de elementos puede dar acceso a partes peligrosas al tacto. El kit no debe ser utilizado hasta que haya finalizado por completo su instalación
	Si el kit se utiliza de manera que no se especifica por el fabricante, la protección asegurada por el mismo puede verse comprometida.
	<b>¡IMPORTANTE!</b>
	Es imprescindible respetar el diseño y la arquitectura de cada kit. Cada kit ha sido diseñado para ser instalado de una forma concreta, con un número de módulos en serie y strings por inversor. La modificación de la arquitectura planteada en cada kit puede provocar daños eléctricos en los equipos y daños físicos a las personas.
	<b>¡IMPORTANTE!</b>
	<b>¡IMPORTANTE:</b> Mantener la polaridad positivo y negativo indicada en los bornes de los módulos.

	<b>IMPORTANT!</b>
	The unit must be disconnected from its power supply sources (power supply and measurement) before undertaking any installation, repair or handling operations on the kit's connections. Contact the after-sales service if you suspect that there is an operational fault in any of the kit units.
	The manufacturer of the kit is not responsible for any damage resulting from failure by the user or installer to heed the warnings and/or recommendations set out in this manual, nor for damage resulting from the use of non-original products or accessories or those made by other manufacturers.
	<b>IMPORTANT!</b>
	It is recommended to refer to the specific manuals of the units that make up the kit before carrying out the installation.
	<b>IMPORTANT!</b>
	Take into account that when the device is connected, the terminals may be hazardous to the touch, and opening the covers or removing elements may provide access to parts that are dangerous to the touch. Do not use the kit until it is fully installed
	If the kit is not used according to the manufacturer's instructions, the protection assured by the kit may be compromised.
	<b>IMPORTANT!</b>
	It is essential to respect the design and architecture of each kit. Each kit has been designed to be installed in a specific way, with a certain number of modules connected in series and a certain number of strings per inverter. Modifying the architecture envisioned for each kit could cause electrical damage to units and physical harm to people.
	<b>IMPORTANT!</b>
	<b>IMPORTANT:</b> Maintain the positive and negative polarity indicated in the module's terminals.


### Características técnicas / Technical features

Características técnicas	Technical features	8-S	8-S-PRO	10-S	10-S-PRO
PV	PV	8.25 kWp	9.0 kWp	10.5 kWp	11.0 kWp
Inversor	Inverter	8 kW	8 kW	10 kW	10 kW
Red	Grid	3 x 400 V	3 x 400 V	3 x 400 V	3 x 400 V
Superficie	Surface	54.1 m <sup>2</sup>	59.04 m <sup>2</sup>	68.8 m <sup>2</sup>	72.16 m <sup>2</sup>
Peso total	Total weight	876 kg	951 kg	1101 kg	1151 kg
Bulto 1	Package 1				
Unidades	Units	1	1	1	1
Dimensiones	Dimensions	1290 x 1730 x 400 mm	1290 x 1730 x 400 mm	1290 x 1730 x 400 mm	1290 x 1730 x 400 mm
Peso	Weight	51 kg	51 kg	51 kg	51 kg
Bulto 2	Package 2				
Unidades	Units	1	1	1	1
Dimensiones	Dimensions	1290 x 1730 x 1140 mm	1290 x 1730 x 1140 mm	1290 x 1730 x 1140 mm	1290 x 1730 x 1140 mm
Peso	Weight	520 kg	520 kg	520 kg	520 kg
Bulto 3	Package 3				
Unidades	Units	1	1	1	1
Dimensiones	Dimensions	1290 x 1730 x 380 mm	1290 x 1730 x 500 mm	1290 x 1730 x 740 mm	1290 x 1730 x 820 mm
Peso	Weight	140 kg	200 kg	320 kg	360 kg
Estructura	Structure				
Peso	Weight	165 kg	180 kg	210 kg	220 kg

### Tabla de componentes del Kit / Kit components table

Tabla de componentes		Components table	8-S	8-S-PRO	10-S	10-S-PRO
CDP	Control dinámico de potencia	Dynamic power control	CDP-0 / CDP-G	CDP-0 / CDP-G	CDP-0 / CDP-G	CDP-0 / CDP-G
AN1	Analizador de redes	Power analyzer	CVM-MINI-MC	CVM-MINI-MC	CVM-MINI-MC	CVM-MINI-MC
CT1, CT2	Transformador de corriente MC3	Current transformer MC3	63 A	63 A	63 A	63 A
INV1	Inversor trifásico	Three-phase inverter	8 kW / 3 x 400 V~	8 kW / 3 x 400 V~	10 kW / 3 x 400 V~	10 kW / 3 x 400 V~
Pr1, Pr2	Protección sobretensión DC	DC overvoltage protection	40 kA / 1000 V ---	40 kA / 1000 V ---	40 kA / 1000 V ---	40 kA / 1000 V ---
Pr3	Protección sobretensión AC	AC overvoltage protection	40 kA / 400 V~	40 kA / 400 V~	40 kA / 400 V~	40 kA / 400 V~
Str1, Str2, Str3, Str4	Módulos fotovoltaicos	Photovoltaic modules	3 x 11 x 250 Wp	3 x 12 x 250 Wp	3 x 14 x 250 Wp	4 x 11 x 250 Wp
F1, F2, F3, F4, F5, F6, F7, F8 <sup>(1)</sup>	Fusibles seccionadores	Disconnectors fuse	10 A	10 A	10 A	10 A
M1 <sup>(1)</sup>	Magnetotérmico 4P	Circuit breaker 4P	25 A	25 A	25 A	25 A
M2, M3 <sup>(1)</sup>	Magnetotérmico 2P	Circuit breaker 2P	10 A	10 A	10 A	10 A
D1 <sup>(1)</sup>	Diferencial 4P	Earth leakage switch 4P	300 mA	300 mA	300 mA	300 mA
C1 <sup>(1)</sup>	Contactador 4P	Contactador 4P	40 A	40 A	40 A	40 A

<sup>(1)</sup> Incluido en Combiner Box CDP CB T-0-0-1-25-300 (opcional) / Included in Combiner Box CDP CB T-0-0-1-25-300 (optional)



\*Solo montar en kit EFM-CDP 10-S-PRO / only mount Kit EFM-CDP 10-S-PRO



¡IMPORTANTE!

En el circuito de continua, se recomienda utilizar cable de 4mm<sup>2</sup> de sección cuando solo haya 1 string.



IMPORTANT!

We recommend using a cable with a 4 mm<sup>2</sup> cross-section in the DC circuit when there is only 1 string.



¡IMPORTANTE!

¡IMPORTANTE: Mantener la polaridad positiva y negativa indicada en los bornes de los módulos.



IMPORTANT!

IMPORTANT: Maintain the positive and negative polarity indicated in the module's terminals.

